

501 KAR 7:070. Safety; emergency procedures.

RELATES TO: KRS 441.045, 441.055

STATUTORY AUTHORITY: KRS 196.035, 197.020, 441.055

NECESSITY, FUNCTION, AND CONFORMITY: KRS 441.055(1) requires the Department of Corrections to promulgate administrative regulations establishing minimum standards for jails that house state prisoners. This administrative regulation establishes safety and emergency procedures to be followed in restricted custody centers.

Section 1. Policy and Procedure. (1) Each center shall have a written policy and procedure that specifies fire prevention practices to provide for the safety of prisoners, visitors, and jail employees. The policy shall include:

- (a) A fire emergency planning session for jail employees at least quarterly;
 - (b) Maintaining written documentation of the fire planning session including evacuation, fire drills, and other procedures covered during this session;
 - (c) A fire safety inspection by the department at least once a year;
 - (d) Inspection and testing of fire protection equipment by a qualified person at least annually with visual inspections by jail personnel monthly;
 - (e) Being a tobacco-free facility; and
 - (f) An evacuation plan coordinated with local fire officials and approved by the department.
- (2) Each center shall have written policy and procedures for emergency situations including:
- (a) Escape;
 - (b) Hostage taking;
 - (c) Riot;
 - (d) Food poisoning;
 - (e) Civil disturbance in the community;
 - (f) Natural disaster;
 - (g) Suicide;
 - (h) Other death and disorder; and
 - (i) Mass evacuation disaster plan.

Section 2. Physical Plant. (1) The center shall comply with the Kentucky Building Code, incorporated by reference in 815 KAR 7:120. An existing center for which approval has been granted may continue without change, except if a significant alteration, addition, or change of occupancy occurs.

- (2) Each exit shall be:
 - (a) Distinctly and permanently marked;
 - (b) Visible at all times;
 - (c) Kept clear; and
 - (d) Maintained in usable condition.
- (3) Each center shall have equipment necessary to maintain essential lights, power, HVAC, and communications in an emergency situation or shall initiate procedures outlined in their emergency plan.
- (4) Each center shall have a fire alarm and smoke detection system.
- (5) Each area shall have an automatic fire extinguishing system. (13 Ky.R. 822; eff. 11-11-1986; Am. 27 Ky.R. 1582; 2141; eff. 2-15-2001; 31 Ky.R. 1574; 1807; eff. 5-26-2005; 34 Ky.R. 2481; eff. 8-1-2008; 37 Ky.R. 2979; 38 Ky.R. 587; eff. 10-7-2011; 42 Ky.R. 1966; 2351; eff. 3-4-2016.)